


BC BUILDING CODE INTERPRETATION COMMITTEE

A joint committee with members representing
AIBC, APEGBC, BOABC, POABC

File No: 12-0096

INTERPRETATION

Page 1 of 1

| | |
|---|--|
| Interpretation Date: | March 21, 2017 |
| Building Code Edition: | BC Building Code 2012 |
| Subject: | Radon Gas Termination |
| Keywords: | Radon, vent pipe, termination, air inlet |
| Building Code Reference(s): | 9.13.4.3.(3)(b)(ii) |
| Question: | <p>Sub-clause 9.13.4.3.(3)(b)(ii) requires that the termination of a radon vent pipe be not less than 1 m above and not less than 3.5 m in any other direction to any air inlet, door or openable window.</p> <p>Does this requirement apply to an air inlet that is used to supply combustion air to a furnace?</p> |
| Interpretation: | <p>Yes</p> <p>The term "any air inlet" in sub-clause 9.13.4.3.(3)(b)(ii) includes air inlets that supply fresh air to the building as well as air inlets that provide combustion air to a furnace within the building.</p> <p> _____ R. J. Light, Committee Chair</p> |
| <p>The views expressed are the consensus of the joint committee with members representing AIBC, APEGBC, BOABC, and POABC, which form the BC Building Code Interpretation Committee. The purpose of the committee is to encourage uniform province wide interpretation of the BC Building Code. These views should not be considered as the official interpretation of legislated requirements based on the BC Building Code, as final responsibility for an interpretation rests with the local <i>Authority Having Jurisdiction</i>. The views of the joint committee should not be construed as legal advice.</p> | |