BC BUILDING CODE INTERPRETATION COMMITTEE

A joint committee with members representing AIBC, APEGBC, BOABC, POABC

File No: 06-0069 INTERPRETATION Page 1 of 1

Interpretation Date:	November 16, 2010
Building Code Edition:	BC Building Code 2006
Subject:	Clearance for exit door swings at exit stair landing
Keywords:	Door swing, Stair width
Building Code Reference(s):	3.4.3.3.(2); 3.4.3.3.(4); 3.4.6.10.(1)

Question:


Can an encroachment of a handrail allowed by Sentence 3.4.3.3.(4) project into the required width of means of egress described by Sentence 3.4.3.3.(2)?

Interpretation:

Yes.

Article 3.4.3.3. describes acceptable reductions in exit width. Sentence 3.4.3.3.(2) allows reduction of the exit width by a door swing into the landing to not less than 750 mm. Sentence 3.4.3.3.(4) allows handrails & construction below the handrails to project up to 100 mm into the required exit width. The provisions of both Sentences (2) & (4) can be applied simultaneously resulting in clear exit width of 650 mm.

Sentence 3.4.6.10.(1) also requires the swing of the door to be setback 300 mm from the first riser.



R. J. Light. Committee Chair

The views expressed are the consensus of the joint committee with members representing AIBC, APEGBC, BOABC, and POABC, which form the BC Building Code Interpretation Committee. The purpose of the committee is to encourage uniform province wide interpretation of the BC Building Code. These views should not be considered as the official interpretation of legislated requirements based on the BC Building Code, as final responsibility for an interpretation rests with the local Authority Having Jurisdiction. The views of the joint committee should not be construed as legal advice.

1107875 / 2010-10-28