

**BC BUILDING CODE INTERPRETATION COMMITTEE
AIBC, APEGBC, BOABC, POABC**

INTERPRETATION

Interpretation Date:	June 20, 2001	File No.: 98-0023
Building Code Edition:	BC Building Code 1998	
Subject:	Protection at urinals	
Keywords:	Urinals, wall protection	
Building Code Reference(s):	7.4.3.1.(1), 3.7.4.6.(1)	Page 1 of 1

Question:

1. What are the clearances to a sidewall for a urinal?
2. Does a sidewall within 900 mm require impervious material?
3. How far around the corner would the impervious material extend?
4. What is the front clearance from a urinal to another obstruction?

Interpretation:

While it is not referenced in the 1998 BCBC, we recommend that the sidewall clearance should be 300 mm (12 inches) from the centre of the urinal to the wall or other obstruction. This would be consistent with previous Factories Act and agrees with the *fixture* manufactures who indicate 600 mm (24 inches) on centre.

Article 3.7.4.6. of the 1992 BCBC indicates impervious material is required from the edge of the urinal for 900 mm (36 inches) in all horizontal directions, which would include a sidewall within 900 mm. (36 inches)

The impervious material on the sidewall must extend to 900 mm (36 inches) in front of the projected outline of the urinal.

While they are not referenced in the 1998 BCBC, the *fixture* clearances indicated in the 1992 BC Plumbing Code sentence 4.3.6.(1)(2)(3) for the front of *fixture* is 450 mm (18 inches) which should be applicable to urinals also. These clearances are consistent with CMHC guidelines. In food preparation areas where sanitation could be compromised, the Health Act can offer some support.

NOTE: The dimensions herein do not apply to washrooms designed for use by persons with disabilities.



R.J. Light, Committee Chair

The views expressed are the consensus of the joint committee of AIBC, APEGBC, BOABC, and POABC, which form the BC Building Code Interpretation Committee. The purpose of the committee is to encourage uniform province wide interpretation of the BC Building Code. These views should not be considered as the official interpretation of legislated requirements based on the BC Building Code, as final responsibility for an interpretation rests with the local *Authority Having Jurisdiction*. The views of the joint committee should not be construed as legal advice; for that purpose, the inquirer should seek the opinion of a qualified lawyer.