
BC BUILDING CODE INTERPRETATION COMMITTEE AIBC, APEGBC, BOABC, POABC

File No: 98-0061	INTERPRETATION	Page 1 of 1	
Interpretation Date:	October 16, 2002		
Building Code Edition:	BC Building Code 1998		
Subject:	Trap cleanouts		
Keywords:	Cleanouts, Access		
Building Code Reference(s):	7.2.3.1.(3)(a)(b); 7.2.10.3.(2	7.2.3.1.(3)(a)(b); 7.2.10.3.(2); 7.4.7.1.(1)	

Question:

The 1998 BC Building Code Clauses 7.2.3.1.(3)(a)(b) indicates the cleanout requirements for traps serving lavatories, sinks and laundry trays.

Where the fixture outlet pipe and trap are removable within the cabinet space below the fixture served, would the installation be considered to meet the code intent?



Interpretation:

The intent of the code is to provide easy removal for trap cleaning. Therefore, the installation method illustrated in the question meets this intent for trap access only providing approved removable fittings are used where noted. This installation method would require that all removable piping and fittings be kept within the immediate cabinet space underneath the fixture.

R. J. Light, Committee Chair

The views expressed are the consensus of the joint committee of AIBC, APEGBC, BOABC, and POABC, which form the BC Building Code Interpretation Committee. The purpose of the committee is to encourage uniform province wide interpretation of the BC Building Code. These views should not be considered as the official interpretation of legislated requirements based on the BC Building Code, as final responsibility for an interpretation rests with the local *Authority Having Jurisdiction*. The views of the joint committee should not be construed as legal advice.