


BC BUILDING CODE INTERPRETATION COMMITTEE

A joint committee with members representing
AIBC, APEGBC, BOABC, POABC

File No: 12-0058

INTERPRETATION

Page 1 of 1

Interpretation Date:	June 16, 2015
Building Code Edition:	BC Building Code 2012
Subject:	Elevator in a walkway between buildings
Keywords:	Elevator, Walkway between Buildings
Building Code Reference(s):	3.2.3.19.
Question:	<p>This project contains 2 separate buildings that are connected with an above ground walkway as described in Article 3.2.3.19.</p> <p>Is it permitted to have an elevator connected to the walkway?</p>
Interpretation:	<p>Yes</p> <p>There are no restrictions in the building code that would prevent an elevator from being connected to an above ground walkway between 2 buildings.</p>
 R. J. Light, Committee Chair	
<p>The views expressed are the consensus of the joint committee with members representing AIBC, APEGBC, BOABC, and POABC, which form the BC Building Code Interpretation Committee. The purpose of the committee is to encourage uniform province wide interpretation of the BC Building Code. These views should not be considered as the official interpretation of legislated requirements based on the BC Building Code, as final responsibility for an interpretation rests with the local <i>Authority Having Jurisdiction</i>. The views of the joint committee should not be construed as legal advice.</p>	
1107875 / 2015-06-20	