**BC BUILDING CODE INTERPRETATION COMMITTEE** 

A joint committee with members representing AIBC, EGBC, BOABC

INTERPRETATION	Page 1 of 1
February 21, 2023	
BC Building Code 2018, Book II: PI (BCPC) and BC Building Code Boo	
Connection of a Radon Vent to Plumbing System Vent	
Radon Vent, Venting System, DWV	/
Division A Part 1, 1.4.1.2.(1), 9.13.4., 5.4.1.1.(1)(e)	
	February 21, 2023 BC Building Code 2018, Book II: Pl (BCPC) and BC Building Code Boo Connection of a Radon Vent to Plu Radon Vent, Venting System, DWV

## **Question:**

Can a radon vent pipe connect to a plumbing vent to reduce the number of roof penetrations in a building?

## Interpretation:

No.

The defined term of a venting system is as follows:

"Venting system means an assembly of pipes and fittings that connects a drainage system with outside air for circulation of air and protection of trap seals in a drainage system."

Since a radon vent does not connect to a drainage system (it connects to a sub-floor depressurization system), it does not fit the above definition.

Further to the above, a fan may also be installed to aid the sub-floor depressurization system which could result in the failure of the trap seals installed at fixtures, which could lead to either sewer gas or radon entering the building.

Par Sheke

Patrick Shek, P.Eng., CP, FEC, Committee Chair

The views expressed are the consensus of the joint committee with members representing AIBC, EGBC and BOABC, which form the BC Building Code Interpretation Committee. The Building and Safety Standards Branch, Province of BC and the City of Vancouver participate in the committee's proceedings with respect to interpretations of the BC Building Code. The purpose of the committee is to encourage uniform province wide interpretation of the BC Building Code. These views should not be considered as the official interpretation of legislated requirements based on the BC Building Code, as final responsibility for an interpretation rests with the local *Authority Having Jurisdiction*. The views of the joint committee should not be construed as legal advice.

2023-03-23