BC BUILDING CODE INTERPRETATION COMMITTEE

A joint committee with members representing AIBC, EGBC, BOABC

File No: 18-0299 INTERPRETATION Page 1 of 1

Interpretation Date:	February 13, 2024
Building Code Edition:	BC Building Code 2018, Book II: Plumbing Systems (BCPC) and BC Building Code Book I: General
Subject:	Bidets – Public Use
Keywords:	Bidet, Public Use
Building Code Reference(s):	2.6.3.2(1), Table 2.6.3.2A, 2.6.3.2.(2). of the BCPC

Question:

Since there are no fixture unit values listed in the public use column of Table 2.6.3.2.-A for a bidet, does this mean a bidet may only be installed in a private bathroom?

Interpretation:

No.

Table 2.6.3.2.-A is used to establish the hydraulic load, expressed in fixture units, for a given fixture (for sizing the water distribution system) and does not limit the use of fixtures. There are no limitations within the BCPC restricting the use of a bidet to bathrooms intended for the use of one family or an individual (private use) only.

The fixture unit value assigned to a bidet installed for public use can be determined in accordance with Sentence 2.6.3.2.(2) using Table 2.6.3.2.-D.

Patrick Shek, P.Eng., CP, FEC, Committee Chair

Pax Skek

The views expressed are the consensus of the joint committee with members representing AIBC, EGBC and BOABC, which form the BC Building Code Interpretation Committee. The Building and Safety Standards Branch, Province of BC and the City of Vancouver participate in the committee's proceedings with respect to interpretations of the BC Building Code. The purpose of the committee is to encourage uniform province wide interpretation of the BC Building Code. These views should not be considered as the official interpretation of legislated requirements based on the BC Building Code, as final responsibility for an interpretation rests with the local *Authority Having Jurisdiction*. The views of the joint committee should not be construed as legal advice.

2024-02-28